



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA192946

Date of Issue: 28 November 2019

Class Description: Non-Prescribed

Product Description: Surge Protection Device

Additional Models	Trade Name	Rating
V20-3-320	OBO BETTERMANN	Uc (50/60Hz) L-N: 320V AC; In L-N: 20kA; I _{max} L-N: 40kA; Up L-N: ≤1.4kV;
V20-3-385	OBO BETTERMANN	Uc (50/60Hz) L-N: 385V AC; In L-N: 20kA; I _{max} L-N: 40kA; Up L-N: ≤1.7kV;
V20-4+FS-280	OBO BETTERMANN	Uc (50/60Hz) L-N: 280V AC; In L-N: 20kA; I _{max} L-N: 40kA; Up L-N: ≤1.3kV;
V20-4+FS-385	OBO BETTERMANN	Uc (50/60Hz) L-N: 385V AC; In L-N: 20kA; I _{max} L-N: 40kA; Up L-N: ≤1.7kV;
V20-4-385	OBO BETTERMANN	Uc (50/60Hz) L-N: 385V AC; In L-N: 20kA; I _{max} L-N: 40kA; Up L-N: ≤1.7kV;

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 28-11-19 192946/7